

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Teragren, LLC

12715 Miller Road NE, Brainbridge Island, WA, USA; Longyu XinYuan Bamboo and Wooden Products Co., Ltd., Xikou Industry Zone, Longyu, Zhejiang Province, China; Zhejiang XinYuan Bamboo Products Co., Ltd., Tanghe Bridge, Hanggai Town, Zhejiang Province, China

For the following product(s):

See Addendum

This product meets all of the necessary qualifications to be certified for the following claim:

## **FloorScore®**

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-01878

Valid from: February 1, 2015 to January 31, 2016

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in blue ink that reads "Robert J. Hrubes".

Robert J. Hrubes, Ph.D., Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

## Certification Addendum

# Teragren, LLC

Certification: Registration # SCS-FS-01878 | Valid from: February 1, 2015 to January 31, 2016

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

### Addendum **FloorScore®**

#### Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.1-2010)

### Products: **Bamboo Flooring and Accessories:**

Xcora® Strand Bamboo, Pureform™ Traditional Vertical Grain Bamboo, Pureform™ Traditional Flat Grain Bamboo, Portfolio Colors, Portfolio Naturals, Synergy® MPL, Synergy® One, Craftsman II, Signature MPL, Elements, Synergy Wide Plank, Studio

*Includes Unfinished and Prefinished flooring manufactured with urea-formaldehyde, phenol-formaldehyde, formaldehyde-free (EPI), or a combination of these adhesives. Prefinished products may be coated with colored stains and finished with a UV cured polyurethane coating.*